



**Specification**

1. The compressor must have at least 4 feet of clearance around all side for proper ventilation and cooling.
2. The compressor must be installed on a smooth, level surface capable of supporting the gross weight of the machine.

|   |          |                           |           |
|---|----------|---------------------------|-----------|
| <b>UNLESS OTHERWISE SPECIFIED</b>   |          |                           |           |
| TOLERANCE ON ANGLES: +/- 0.5 DEGREE   |          |                           |           |
| MACHINED PARTS TOLERANCE: +/- 0.03 in   |          |                           |           |
| SHEETMETAL TOLERANCE: +/- .13 in  |          |                           |           |
| FINISH ON MACHINED SURFACES  |          |                           |           |
| DESIGN  | STD      |                           |           |
| CHECK   | AUDITING | APPROVE                   |           |
| <b>KRSB-40/50 FS/VSD</b>  |          | <b>Outline Dimensions</b> |           |
| PHASE SIGN  | WEIGHT   | SCALE                     | REF. ONLY |
| S   |          | 1:10                      |           |
| SHEET 1   | OF 1     | NEXT ASSE                 |           |
|                              |          |                           |           |